



SAMPLE EVALUATION REPORT

S.No	Item Description	M/s. Steel Case Bangalore		M/s. Citizen Industries Pvt. Ltd Bangalore		M/s. Obul Reddy & sons Tirupati		M/s. ART LAB Hyderabad		M/s. Orientallabs Retail Services Pvt. Ltd Kolkata	
		Complied (Yes/ No)	Remarks	Complied (Yes/ No)	Remarks	Complied (Yes/ No)	Remarks	Complied (Yes/ No)	Remarks	Complied (Yes/ No)	Remarks
1	Granite top side table with under bench fixed storage cabinets & power sockets 1520 mm (L) x 920 mm (W) x 900 mm (H) BASE CABINET -750X549X895mm- 1DW/2DR – 2 Nos	Sample items not submitted		Sample items not submitted		Sample items not submitted		Yes	Self-closing Hinge locks are to be provided. Vendor has accepted to provide the self-closing hinge locks for all the drawers of the storage cabinets as per the committee's suggestion.	Sample items not submitted	
2	Granite top workbench with power sockets, Under storage cabinets & leg space  1800 mm(L) x 900 mm (W) x 900 mm (H) BASE CABINET -600X549X895mm- 1DW/1DR – 2 Nos							Yes	Self-closing Hinge locks are to be provided. Vendor has accepted to provide the self-closing hinge locks for all the drawers of the storage cabinets as per the committee's suggestion.		
3	Granite top workbenches without storage cabinets 1520 mm (L) x 920 mm (W) x 900 mm (H) KNEE SPACE – 2 Nos							Yes			
4	Movable under bench chemical cabinets 600 mm (L) x 530 mm (D) x 650 mm (H) MOVABLE PP CHEMICAL CABINET WITH VENT HOLE - 600X530X650mm-1DW/2DR, X= WITH CASTOR & TOP CLOSED, L=WITH LOCK, G=MOC:GI							Yes	Self-closing Hinge locks are to be provided. Vendor has accepted to provide the self-closing hinge locks for all the drawers of the storage cabinets as per the committee's suggestion.		
5	Reagent shelves on the work benches 900 mm (L) x 250 mm (D) x 600 mm (H) 2 TIER REAGENT RACK WITH UPRIGHT							Yes			
6	Acid/Alkali corrosive resistant storage cabinet 1970 mm (H) x 900 mm (W) x 600 (D) 90 GALLONS PP ACID CABINET 900x600x1970mm WITH BI-FOLD SHELF CLOSE DOORS WITH VENT							Yes	Magnetic lock should be provided for the Acid storage cabinets. Door hinges should have the Teflon coating to avoid rusting/corrosion. The vendor has agreed to provide as per the committee's suggestion.		

7	Solvent storage cabinet (flammable storage cabinet) 1970 mm (H) x 900 mm (W) x 600 mm (D)		Yes	
8	Full-height storage cabinets 900 mm (W) x 600 mm (D) x 2000 mm (H) TALL UNIT SWINGING PANEL WITH VENT HOLE AND LOUVERS AT BOTTOM HAVING 5 NOS. OF HEIGHT ADJUSTABLE SHELVES AND 6 NOS. OF PP TRAYS-900X600X2000mm, X= FRAMED GLASS DOOR - 1 No		Yes	Doors should be properly closing without gap. Should have the self-closing hinge locks. Vendor has agreed to provide as per the committee's suggestion.
9	Double door wall mounted storage cabinets 750 mm (L) x 400 mm (W) x 750 mm (H) WALL CABINET FRAMED GLASS SWINGING DOOR - 750X400X750mm, L=WITH LOCK.		Yes	Doors should be properly closing without gap. Should have the self-closing hinge locks. Vendor has agreed to provide as per the committee's suggestion.
10	Gas cylinder storage cabinets 4-cylinder cabinets 90 MINS GAS CYLINDER CABINET HOLDING 4 GAS CYLINDERS-1198x615x2050mm WITH VENT, GAS LEAK SENSOR, WITH ALL ACCESSORIES		Yes	2-cylinder cabinet is submitted for sample evaluation with EN certifications as per the tender specifications. Vendor has given self-declaration to adhere with the tender specifications.
11	Granite top workbench with sink and peg board  Table dimensions: 1500 mm(L) x 920 mm(D) x 900 mm(H). Sink dimensions: 560 mm(L) x 360 mm(D) x 300 mm (H) BASE SINK CABINET- 750X549X895mm-2DR - 1 No BASE SINK CABINET-750X549X895mm-2DR - 1 No BASE CABINET-750X549X895mm-2DR - 1 No		Yes	
12	Laboratory stools 16-inch dia revolving chair with adjustable height.		Yes	
13	Anti-vibration tables 1520 mm (L) x 920 mm (W) x 920 mm (H) WITH 80mm THICK GRANITE WORKTOP, X=WITH ANTI-VIBRATION PADS AT BOTTOM		Yes	Anti-vibration table of dimensions - 920 mm (L) x 640 mm (W) x 920 mm (H) is submitted for sample evaluation and the vendor has given self-declaration to provide the anti-vibration tables as per the tender specifications.

14	Single sink with peg board 760 mm (W) x 920 mm (D) x 920				Yes	
	Subcommittee Recommendations	Not Recommended as the bidder did not submit the samples.	Not Recommended. The bidder could not submit the samples or could not even provide the video proof of supply of similar furniture.	Not Recommended as the bidder did not submit the samples.	Recommended by the Tender evaluation committee to open the financial bid.	Not Recommended as the bidder did not submit the samples.

Since only one bidder has submitted the samples as per the tender no. IITT/EU/2023-24/7, the tender evaluation committee has evaluated the samples and recommended to open the financial bid submitted by M/s. ART LAB.